

Monitoring Violation(s) Annual Notice-

Important Information about your Drinking Water

RE: Violation section on page 6 (RTCR)

Monitoring Requirements Not Met for The City of Hooks

Our system failed to collect every required coliform sample. Although this incident was not an emergency, as our customers, you have a right to know what happened and what we did (are doing) to correct this situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the Month of February 2021, we did not complete all monitoring or testing for coliform bacteria and therefore cannot be sure of quality of your drinking water during that time.

What should I do?

There is nothing you need to do at this time. You may continue to drink the water. If a situation arises where the water is no longer safe to drink, we are required to notify you in 24 hours.

What is being done?

During the Winter Storm, the City of Hooks failed to collect the monthly samples required by the State. We collected special samples due to the boil order we were under, however, those sample were not allowed to be used as our monthly samples.

Actions taken: We collected every required coliform sample in March 2021 and are no longer in violation. We know now, we can not use special samples for our monthly samples and will not let this happen again. For more information, please contact Andria Whitehurst at 903-547-2105 or City of Hooks, Attn: Andria Whitehurst at P.O. Box 37 Hooks, Texas 75561.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly.

This Notice is being sent to you by the City of Hooks.

Public Water System # TX0190002.

Distributed: by July 1, 2021